



*Pianco Sand & Stone Corp.*

151 SOUTH STREET  
MANORVILLE, NEW YORK 11949

MASONRY-MORTAR SAND

<u>SIEVE SIZE</u>	<u>PERCENT PASSING</u>	<u>ASTM C-144 SPECIFICATIONS</u>
4	100.0	100
8	98.7	95-100
16	93.3	70-100
30	72.8	40-75
50	31.4	10-35
100	10.1	2-15

SOURCE # 10-98F  
SAND TEST # 04AF30